



Nachrüstung / Neuanlage

Einwohner EW	Mindestvolumen m ³	Einbaumaße (mm)	
		Innen-Ø	Wassertiefe* (WT)
1–4	4,0	2000	≥ 1330
1–4	4,0	2300	≥ 1000
1–4	4,0	2500	≥ 1000
6	4,2	2000	≥ 1400
6	4,2	2300	≥ 1050
6	4,2	2500	≥ 1000
8	5,6	2000	≥ 1870
8	5,6	2300	≥ 1400
8	5,6	2500	≥ 1180

Einwohner EW	Mindestvolumen m ³	Einbaumaße (mm)	
		Innen-Ø	Wassertiefe* (WT)
8	5,6	2800	≥ 1000
10	7,0	2300	≥ 1750
10	7,0	2500	≥ 1480
10	7,0	2800	≥ 1170
12	8,4	2500	≥ 1770
12	8,4	2800	≥ 1410
14	9,8	2800	≥ 1640
16	11,2	2800	≥ 1880

Aktuelle Bauaufsichtliche Zulassungen finden Sie auf www.atbwater.de

*maximal 2000 mm